



Industrie Service

CERTIFICATE

(Certificate of conformity with technical requirements in:)
API STANDARD 607 SEVENTH EDITION, JUNE 2016

Certificate No.:267097

Ref. Test report No.: 267098

Name and postal address of manufacturer: **DBV Valve Co., Ltd.**
Tangtou Village, Oubei Street, Yongjia County,
PC: 325102, Wenzhou City, Zhejiang Province, P. R. China
(No.96 Fanhua East)

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV SÜD inspector according to requirements of API STANDARD 607 SEVENTH EDITION, JUNE 2016. The testing results of valves meet the requirements of API STANDARD 607 SEVENTH EDITION, JUNE 2016.

1. Description of Test Valve :

Type of Test Valve	Q47F-CL1500 NPS2 Ball Valve
Description of Test Valve	Ball Valve
Valve Size (NPS)	2"
Pressure Rating (Class)	Class 1500
Valve Body Material	ASTM A182 F316

2. Qualified Range of Valves :

Type	Ball Valves
Description of Valves	Ball Valves
Qualified Sizes (NPS) (according to API 607 Table 3)	2" and below, 2 1/2", 3", 4"
Qualified Pressure Ratings(Class) (according to API 607 Table 4)	Class 1500, Class 2500
Qualified Valve Material	According to API 607 7.2
Remark: the technical data of tested valves see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 607 SEVENTH EDITION, JUNE 2016, based upon the result of testing report on above mentioned test valve. The additional valve qualification shall be limited on similar valves of same basic design and construction as the test valves and of the same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal according to API STANDARD 607 SEVENTH EDITION, JUNE 2016, Paragraph 7.

Shanghai, January 10, 2020
(Place, date)



Guilin Chen
TÜV SÜD Industrie Service GmbH
Westendstr. 199
80686 München Germany